



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**CertainTeed Corporation**  
**1400 Union Meeting Road, P.O. Box 1100**  
**Blue Bell, PA 19422-0761**

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: CertainTeed Modified Bitumen Roof Systems over Steel Decks.

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 12-1023.05 and consists of pages 1 through 31.

The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 13-0702.02**  
**Expiration Date: 01/02/18**  
**Approval Date: 12/19/13**  
**Page 1 of 31**

## ROOFING SYSTEM APPROVAL

**Category:** Roofing  
**Sub-Category:** Modified  
**Material:** APP, SBS  
**Deck Type:** Steel  
**Maximum Design Pressure:** -120 psf.

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<b>Product</b>	<b>Dimensions</b>	<b>Test Specification</b>	<b>Product Description</b>
All Weather/Empire Base Sheet	36" x 65'10"; Roll weight: 86 lbs. (2 squares)	ASTM D 4601 Type II UL Type 15	Asphalt coated, fiberglass reinforced base sheet.
Flex-I-Glas™ Base Sheet	36" x 98'9"; Roll weight: 90 lbs. (3 squares)	ASTM D 4601, Type II UL Type G2	Modified Bitumen coated fiberglass base sheet.
Flex-I-Glas™ FR Base Sheet	39 3/8" x 50'; Roll weight: 90 lbs. (1.5 squares)	ASTM D 6163, Grade S, Type I	Modified Bitumen coated fiberglass base sheet.
Flintglas® Ply Sheet Type IV or VI	36" x 164'7"; Roll weight: 40/55 lbs. (5 squares)	ASTM D 2178 Type IV or VI UL Type G1	Fiberglass, asphalt impregnated ply sheet.
Flintlastic STA	39 3/8" x 33'; Roll weight: 90 lbs. (1 square)	ASTM D 6222, Grade S, Type II	Smooth surfaced APP Modified Bitumen membrane with non-woven polyester mat reinforcement for torch application.
Flintlastic GTA, GTA-FR	39 3/8" x 33' 3"; Roll weight: 105 lbs. (1 square)	ASTM D 6222, Grade G, Type II	Granule surfaced APP Modified Bitumen membrane with non-woven polyester mat reinforcement for torch application.
Flintlastic GMS, GMS Premium	39 3/8" x 34' 2"; Roll weight: 100/105 lbs. (1 square)	ASTM D 6164, Grade G, Type II	Granule surfaced SBS Modified Bitumen membrane with non-woven polyester mat reinforcement for mop application.
Flintlastic FR-P, FR-P Premium	39 3/8" x 34' 2"; Roll weight: 105 lbs. (1 square)	ASTM D 6164, Grade G, Type I	Fire resistant, granule surfaced SBS Modified Bitumen Membrane with non-woven polyester mat reinforcement for mop application.
Flintlastic FR Cap Sheet	39 3/8" x 34' 2"; Roll weight: 90 lbs. (1 square)	ASTM D 6163, Grade G, Type I	Fire resistant, granule surfaced SBS Modified Bitumen membrane with fiberglass mat reinforcement for mop applications.
Flintlastic FR Cap T	39-3/8" x 34' 2"; Roll weight: 81lbs. (1 square)	ASTM D6163	Granule surfaced SBS Modified Bitumen membrane with fiberglass mat reinforcement for torch application.



<b><u>Product</u></b>	<b><u>Dimensions</u></b>	<b><u>Test Specification</u></b>	<b><u>Product Description</u></b>
Flintlastic FR Base T	39-3/8" x 33'; Roll Weight: 81lbs. (1.0 squares)	ASTM D6163	Modified Bitumen, coated fiberglass base sheet for torch application.
Flintlastic FR Cap CoolStar	39 3/8" x 34' 2"; Roll weight: 90 lbs. (1 square)	ASTM D 6163	Fire resistant, granule surfaced SBS Modified Bitumen membrane with fiberglass mat reinforcement for mop applications. Covered with reflective CoolStar Coating.
Flintlastic FR Cap T CoolStar	39 3/8" x 34' 2"; Roll weight: 90 lbs. (1 square)	ASTM D 6163	Fire resistant, granule surfaced SBS Modified Bitumen membrane with fiberglass mat reinforcement for torch applications. Covered with reflective CoolStar Coating.
Flintlastic GTA, GTA-FR CoolStar	39 3/8" x 33' 3"; Roll weight: 105 lbs. (1 square)	ASTM D 6222	Granule surfaced APP Modified Bitumen membrane with non-woven polyester mat reinforcement for torch application. Covered with reflective CoolStar Coating.
Flintlastic GMS/GMS Premium CoolStar	39 3/8" x 34' 2"; Roll weight: 100/105 lbs. (1 square)	ASTM D 6164	Granule surfaced SBS Modified Bitumen membrane with non-woven polyester mat reinforcement for mop application. Covered with reflective CoolStar Coating.
Flintlastic FR-P/FR-P Premium CoolStar	39 3/8" x 34' 2"; Roll weight: 105 lbs. (1 square)	ASTM D 6164	Fire resistant, granule surfaced SBS Modified Bitumen Membrane with non-woven polyester mat reinforcement for mop application. Covered with reflective CoolStar Coating.
Ultra Poly SMS	36" x 64' 4" (2 squares)	ASTM D 6164, Grade S, Type I	Smooth surfaced SBS Modified Bitumen Membrane with non-woven polyester mat reinforcement for mop applications.
GlasBase™ Base Sheet	36" x 98' 9"; Roll weight: 69 lbs. (3 squares)	ASTM D 4601 UL Type G2	Asphalt coated, fiberglass base sheet.
PolySMS Base Sheet	39 3/8" x 64' 4"; Roll weight: 90 lbs. (2 squares)	ASTM D 4601 Grade S, Type II UL Type G2	Modified Bitumen coated polyester base sheet.
Yosemite® Buffer Base Sheet	36" x 32' 10"; Roll weight: 90 lbs. (1 square)	ASTM D 3909 ASTM D 4897 UL Type 30	Mineral Surfaced fiberglass reinforced buffer sheet.
Black Diamond™ Base Sheet	36" x 68' 7"; Roll weight: 78 lbs. (2 squares)	ASTM D 1970	Self-adhering fiberglass reinforced modified bitumen base sheet

## APPROVED INSULATIONS:

<b>TABLE 2</b>		
<b>Product Name</b>	<b>Product Description</b>	<b>Manufacturer (With Current NOA)</b>
Fesco Board	Expanded mineral fiber insulation	Johns Manville Corp.
High Density Wood Fiberboard	Wood fiber insulation board	generic
Perlite Insulation	Perlite insulation board	generic
EPS	Type IX 1.8 pcf. Expanded Polystyrene Insulation	Generic
DensDeck, DensDeck Prime	Water resistant gypsum board	Georgia-Pacific Gypsum LLC
H-Shield	Polyisocyanurate foam insulation	Hunter Panels, LLC
ENRGY 3, ENRGY 3 25 PSI	Polyisocyanurate foam insulation	Johns Manville Corp.
Multi-Max FA-3	Polyisocyanurate roof insulation	RMax Operating, LLC
FlintBoard ISO	Polyisocyanurate foam insulation	CertainTeed Corp.
ACFoam-II	Polyisocyanurate foam insulation	Atlas Roofing Corporation
SECUROCK Gypsum-Fiber Roof Board	Gypsum insulation	US Gypsum

## APPROVED FASTENERS:

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	Dekfast 12	Insulation fastener	Various	SFS Intec, Inc.
2.	Dekfast 14	Insulation fastener	Various	SFS Intec, Inc.
3.	Dekfast Galvalume Steel Hex Plate	Galvalume AZ50 steel plate	2 7/8" x 3 1/4"	SFS Intec, Inc.
4.	#12 Standard Roofgrip	Insulation fastener for wood and steel.	Various	OMG, Inc.
5.	#14 Roofgrip Fasteners	Insulation fastener for wood and steel.	Various	OMG, Inc.
6.	3 in. Ribbed Galvalume Plate	Galvalume stress plate.	3" round	OMG, Inc.
7.	AccuTrac Plate	Galvalume stress plate.	3" square	OMG, Inc.
8.	OMG 3 in. Round Metal Plates	Galvalume AZ50 steel plate	3" round	OMG, Inc.
9.	Trufast #14 HD Fastener	Insulation fastener for wood and steel decks	Various	Altenloh, Brinck & Co. U.S., Inc.
10.	Trufast 3" Metal Insulation Plate	Galvalume AZ50 steel plate	3" round	Altenloh, Brinck & Co. U.S., Inc.
11.	Trufast 2.4" Barbed Metal Seam Plates	Galvalume AZ50 steel plate	2.4" round	Altenloh, Brinck & Co. U.S., Inc.
12.	Trufast #12 DP Fastener	Coated, carbon steel screw	Various	Altenloh, Brinck & Co. U.S., Inc.
13.	Dekfast 15 HS	Coated, carbon steel fastener	Various	SFS Intec, Inc.
14.	Trufast #15 EHD Fastener	Coated, carbon steel screw	Various	Altenloh, Brinck & Co. U.S., Inc.

**EVIDENCE SUBMITTED:**

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	FMRC 4470	J.I. 3Y8A1.AM	03/23/96
	FMRC 4470	J.I. 0D3A3.AM	04/04/97
	FMRC 4470	J.I. 2D0A0.AM	12/23/98
	FMRC 4470	J.I. 1D7A4.AM	11/09/98
Underwriters Laboratories, Inc.	UL 790	R11656	10/25/12
United States Testing Company	ASTM D 5147	97457-4	06/03/88
	ASTM D 5147	97-457-2R	12/02/87
Momentum Technologies, Inc.	ASTM D4601	AX31G8D	09/05/08
	ASTM D6164	AX31G8F	06/05/09
	ASTM D6222	AX31G8G	06/05/09
	ASTM D3909/4897	AX31G8C	09/05/08
Trinity ERD	TAS 114	3513.08.02	08/15/02
	TAS 117 (B)	3503.10.06	10/10/06
	TAS 117	3515.07.03	07/22/03
	TAS 117 (B)	O6490.04.07-R1	06/27/07
	TAS 114 (H)	Letter	04/05/06
	FM 4470, TAS 114	3533.01.06	01/06/06
	FM 4470, TAS 114	3521.07.04	07/29/04
	TAS 117 (B)/ ASTM D6862	C8500SC.11.07	11/30/07
	FM 4470, TAS 114	C8370.08.08	08/19/08
	ASTM D6163/6164/6222/3909	C10080.09.08-R4	03/25/10
	ASTM D6164/4798	C31410.01.11-2	01/10/11
	ASTM D4601	C40050.09.12-1	09/28/12
	ASTM D1970	C40050.09.12-2	09/28/12
	ASTM D5147/4798	C31410.10.10-R1	11/01/12
	ASTM D5147/4798	C31410.01.11-1-R1	11/01/12
	ASTM D4798	C31410.01.11-2A-R1	02/21/13
	ASTM D4798	C31410.12.13	12/05/13
	ASTM D6222	C40050.12.13	12/05/13
PRI Construction Materials Technologies LLC	ASTM D6163	CTC-032-02-01	01/22/08
	ASTM D6163	CTC-066-02-01	08/09/11
	ASTM D6222	CTC-070-02-01	08/09/11
	ASTM D6164/4798	CTC-093-02-01	08/09/11
	ASTM D2178	CTC-122-02-01	03/13/12
	ASTM D2178	CTC-123-02-01	03/13/12
	ASTM D4601	CTC-127-02-01	03/13/12
	ASTM D6163	CTC-128-02-01	06/11/12
	ASTM D6163	CTC-129-02-01	06/11/12
	ASTM D6164	CTC-132-02-01	06/11/12
	ASTM D6164	CTC-162-02-01	05/09/13
	ASTM D6164	CTC-161-02-01	05/09/13
	ASTM D6162	CTC-183-02-01	10/02/13
	ASTM D6164	CTC-190-02-01	12/02/13

## APPROVED ASSEMBLIES:

**Membrane Type:** APP MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. steel

**System Type B(1):** Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

### All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
<b>ACFoam-II, FlintBoard ISO, H-Shield</b>		
Minimum 1.5" thick	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>
Minimum 2" thick	1, 2, 4, 5, 9	1:3.2 ft <sup>2</sup>
<b>ENRGY 3, ENRGY 3 25 PSI</b>		
Minimum 1.4" thick	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>
Minimum 2" thick	1, 2, 4, 5, 9	1:3.2 ft <sup>2</sup>
<b>Approved Perlite Insulation</b>		
Minimum ¾" thick	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>
<b>Approved High Density Wood Fiberboard</b>		
Minimum ½" thick	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>
<b>DensDeck, DensDeck Prime</b>		
Minimum ¼" thick	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>

**Note:** Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
Any of the insulations listed for Base Layer, above.		
Minimum See Base Layer	N/A	N/A

**Note:** Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

**Base Sheet:** One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional)	One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self-adhered or Flintlastic STA torch adhered.
Membrane:	Flintlastic GTA, Flintlastic GTA Coolstar or Flintlastic GTA-FR, Flintlastic GTA-FR Coolstar torch adhered to base or ply sheet.
Surfacing:	Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA: <ol style="list-style-type: none"> <li>1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.</li> <li>2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibered Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.</li> </ol>
Maximum Design Pressure:	-52.5 psf. (See General Limitation #9)



**Membrane Type:** SBS MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. steel

**System Type B(2):** Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, FlintBoard ISO, H-Shield</b>		
Minimum 1.5" thick	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>
Minimum 2" thick	1, 2, 4, 5, 9	1:3.2 ft <sup>2</sup>
<b>ENRGY 3, ENRGY 3 25 PSI</b>		
Minimum 1.4" thick	1, 2, 4, 5	1:2 ft <sup>2</sup>
Minimum 2" thick	1, 2, 4, 5, 9	1:3.2 ft <sup>2</sup>
<b>Approved Perlite Insulation</b>		
Minimum ¾" thick	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>
<b>Approved High Density Wood Fiberboard</b>		
Minimum ½" thick	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>
<b>DensDeck, DensDeck Prime</b>		
Minimum ¼" thick	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>

**Note:** Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any of the insulations listed for Base Layer, above.</b>		
Minimum See Base Layer	N/A	N/A

**Note:** Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

**Base Sheet:** One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional)	One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self-adhered.
Membrane:	One ply of Flintlastic GMS, Flintlastic GMS Coolstar, Flintlastic Premium GMS, Flintlastic Premium GMS Coolstar, Flintlastic FR-P, Flintlastic FR-P Coolstar, Flintlastic Premium FR-P, Flintlastic Premium FR-P Coolstar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet Coolstar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T Coolstar torch adhered to ply sheet
Surfacing:	Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA: <ol style="list-style-type: none"> <li>1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.</li> <li>2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.</li> </ol>
Maximum Design Pressure:	-52.5 psf. See General Limitation #9

**Membrane Type:** APP MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., Grade 33 steel deck is secured to steel supports spaced maximum 5 ft. o.c. with 5/8" paddle welds with weld washers or with Teks 4 fasteners spaced 6" o.c. Side laps are secured with Teks 1 fasteners spaced maximum 30" o.c.

**System Type B(3):** Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ENRGY 3, Multi-Max FA-3, FlintBoard ISO, H-Shield</b>		
<b>Minimum 1.5" thick</b>	<b>1, 2, 4, 5, 9</b>	<b>1:1.33</b>

**Note:** Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Fesco Board</b>		
<b>Minimum ¾" thick</b>	<b>N/A</b>	<b>N/A</b>
<b>Approved High Density Wood Fiberboard</b>		
<b>Minimum ½" thick</b>	<b>N/A</b>	<b>N/A</b>

**Note:** Top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

**Base Sheet:** One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:** One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self-adhered or Flintlastic STA torch adhered.

**Membrane:** Flintlastic GTA, Flintlastic GTA Coolstar or Flintlastic GTA-FR, Flintlastic GTA-FR Coolstar torch adhered to base or ply sheet.

Surfacing:	Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA: <ol style="list-style-type: none"> <li>1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.</li> <li>2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibered Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.</li> </ol>
Maximum Design Pressure:	-52.5 psf. (For Fesco Board) (See General Limitation #7) -67.5 psf. (For High Density Wood Fiberboard) (See General Limitation #7)

**Membrane Type:** SBS MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., Grade 33 steel deck is secured to steel supports spaced maximum 5 ft. o.c. with 5/8" paddle welds with weld washers or with Teks 4 fasteners spaced 6" o.c. Side laps are secured with Teks 1 fasteners spaced maximum 30" o.c.

**System Type B(4):** Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ENRGY 3, Multi-Max FA-3, FlintBoard ISO, H-Shield Minimum 1.5" thick</b>	<b>1, 2, 4, 5, 9</b>	<b>1:1.33</b>

**Note:** Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Fesco Board Minimum ¾" thick</b>	<b>N/A</b>	<b>N/A</b>
<b>Approved High Density Wood Fiberboard Minimum ½" thick</b>	<b>N/A</b>	<b>N/A</b>

**Note:** Top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

**Base Sheet:** One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:  
(Optional)** One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self-adhered.

- Membrane: One ply of Flintlastic GMS, Flintlastic GMS Coolstar, Flintlastic Premium GMS, Flintlastic Premium GMS Coolstar, Flintlastic FR-P, Flintlastic FR-P Coolstar, Flintlastic Premium FR-P, Flintlastic Premium FR-P Coolstar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet Coolstar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T Coolstar torch adhered to ply sheet
- Surfacing: Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA:
1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.
  2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibered Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.
- Maximum Design Pressure: -52.5 psf. (For Fesco Board) (See General Limitation #7)  
-67.5 psf. (For High Density Wood Fiberboard) (See General Limitation #7)

**Membrane Type:** APP MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. steel

**System Type C(1):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Base Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ENRGY 3, ENRGY 3 25 PSI, FlintBoard ISO, H-Shield Minimum 1.5" thick</b>	N/A	N/A
<b>Approved Perlite Insulation Minimum ¾" thick</b>	N/A	N/A
<b>Approved High Density Wood Fiberboard Minimum ½" thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime Minimum ¼" thick</b>	N/A	N/A

**Note:** All layers shall be simultaneously fastened; see top layer below for fasteners and density.

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Approved High Density Wood Fiberboard Minimum ½" thick</b>	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>
<b>Approved Perlite Insulation Minimum ¾" thick</b>	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>
<b>DensDeck, DensDeck Prime Minimum ¼" thick</b>	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional)	One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self-adhered or Flintlastic STA torch adhered.
Membrane:	Flintlastic GTA, Flintlastic GTA Coolstar or Flintlastic GTA-FR, Flintlastic GTA-FR Coolstar torch adhered to base or ply sheet.
Surfacing:	Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA: <ol style="list-style-type: none"> <li>1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.</li> <li>2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibered Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.</li> </ol>
Maximum Design Pressure:	-52.5 psf. See General Limitation #9



**Membrane Type:** SBS MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. steel

**System Type C(2):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Base Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ENRGY 3, ENRGY 3 25 PSI, FlintBoard ISO, H-Shield Minimum 1.5" thick</b>	N/A	N/A
<b>Approved Perlite Insulation Minimum ¾" thick</b>	N/A	N/A
<b>Approved High Density Wood Fiberboard Minimum ½" thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime Minimum ¼" thick</b>	N/A	N/A

**Note:** All layers shall be simultaneously fastened; see top layer below for fasteners and density.

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Approved High Density Wood Fiberboard Minimum ½" thick</b>	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>
<b>Approved Perlite Insulation Minimum ¾" thick</b>	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>
<b>DensDeck, DensDeck Prime Minimum ¼" thick</b>	1, 2, 4, 5, 9	1:2 ft <sup>2</sup>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional)	One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self-adhered.
Membrane:	One ply of Flintlastic GMS, Flintlastic GMS Coolstar, Flintlastic Premium GMS, Flintlastic Premium GMS Coolstar, Flintlastic FR-P, Flintlastic FR-P Coolstar, Flintlastic Premium FR-P, Flintlastic Premium FR-P Coolstar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet Coolstar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T Coolstar torch adhered to ply sheet
Surfacing:	Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA: <ol style="list-style-type: none"> <li>1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.</li> <li>2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.</li> </ol>
Maximum Design Pressure:	-52.5 psf. See General Limitation #9

**Membrane Type:** APP MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., type B, Grade 33 steel, fastened 6" o.c. with puddle welds and washers to steel supports spaced maximum 6 ft. o.c.

**System Type C(3):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ACFoam-II, ENRGY 3, Multi-Max FA-3, FlintBoard ISO, H-Shield Minimum 1.5" thick	2, 5, 9	1:1.33 ft <sup>2</sup>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** One ply of Black Diamond Base Sheet self-adhered.

**Ply Sheet:** One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self-adhered or Flintlastic STA torch adhered.

**Membrane:** Flintlastic GTA, Flintlastic GTA Coolstar or Flintlastic GTA-FR. Flintlastic GTA-FR Coolstar torch adhered to base or ply sheet.

**Surfacing:** Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.

**Maximum Design Pressure:** -82.5 psf. (See General Limitation #7)

**Membrane Type:** SBS MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., type B, Grade 33 steel, fastened 6" o.c. with puddle welds and washers to steel supports spaced maximum 6 ft. o.c.

**System Type C(4):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ACFoam-II, ENRGY 3, Multi-Max FA-3, FlintBoard ISO, H-Shield Minimum 1.5" thick	2, 5, 9	1:1.33 ft <sup>2</sup>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** One ply of Black Diamond Base Sheet self-adhered.

**Ply Sheet:**  
(Optional) One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self-adhered.

**Membrane:** One ply of Flintlastic GMS, Flintlastic GMS Coolstar, Flintlastic Premium GMS, Flintlastic Premium GMS Coolstar, Flintlastic FR-P, Flintlastic FR-P Coolstar, Flintlastic Premium FR-P, Flintlastic Premium FR-P Coolstar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet Coolstar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T Coolstar torch adhered to ply sheet

**Surfacing:** Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibered Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.

**Maximum Design Pressure:** -52.5 psf. (See General Limitation #7)



**Membrane Type:** APP MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. steel

**System Type D(1):** All layers of insulation and base sheet simultaneously attached.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

**Base Insulation Layer (Optional)**

	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ENRGY 3, ENRGY 3 25 PSI, FlintBoard ISO, H-Shield Minimum 1.5" thick</b>	N/A	N/A

**Approved Perlite Insulation**

<b>Minimum ¾" thick</b>	N/A	N/A
-------------------------	-----	-----

**Approved High Density Wood Fiberboard**

<b>Minimum ½" thick</b>	N/A	N/A
-------------------------	-----	-----

**DensDeck, DensDeck Prime**

<b>Minimum ¼" thick</b>	N/A	N/A
-------------------------	-----	-----

**Top Insulation Layer**

	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Approved High Density Wood Fiberboard Minimum ½" thick</b>	N/A	N/A

**Approved Perlite Insulation**

<b>Minimum ¾" thick</b>	N/A	N/A
-------------------------	-----	-----

**DensDeck, DensDeck Prime**

<b>Minimum ¼" thick</b>	N/A	N/A
-------------------------	-----	-----

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base or Flexiglas FR Base mechanically attached as detailed in Fastening #1 or #2, below or one ply of Poly SMS or Ultra Poly SMS mechanically attached as detailed in Fastening #3 or #4, below.

Fastening #1:	OMG #12 Standard Roofgrip or #14 Roofgrip fasteners with OMG 3” Round Metal Plates, Trufast #12 DP Fastener or Trufast #14 HD Fastener with Trufast 3” Metal Insulation Plates, Dekfast 12, Dekfast 14 or Dekfast 15 HS Fasteners with Dekfast Galvalume Steel Hex Plates at a 4" side lap 12" o.c. and two rows staggered in the center of the sheet, 24" o.c.
Fastening #2:	OMG #12 Standard Roofgrip or #14 Roofgrip fasteners with OMG 3” Round Metal Plates, Trufast #12 DP Fastener or Trufast #14 HD Fastener with Trufast 3” Metal Insulation Plates, Dekfast 12, Dekfast 14 or Dekfast 15 HS and with Dekfast Galvalume Steel Hex Plates at a 4" side lap 12" o.c. and one row in the center of the sheet, 18" o.c.
Fastening #3:	OMG #12 Standard Roofgrip or #14 Roofgrip fasteners with OMG 3” Round Metal Plates, Trufast #12 DP Fastener or Trufast #14 HD Fastener with Trufast 3” Metal Insulation Plates, Dekfast 12, Dekfast 14 or Dekfast 15 HS and with Dekfast Galvalume Steel Hex Plates at a 4" side lap 12" o.c. and two rows staggered in the center of the sheet, 36" o.c.
Fastening #4:	Trufast #12 DP Fastener or Trufast #14 HD Fastener with Trufast 3” Metal Insulation Plates at a 4" side lap, 12" o.c.
Ply Sheet: (Optional)	One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self-adhered or Flintlastic STA torch adhered.
Membrane:	Flintlastic GTA, Flintlastic GTA Coolstar or Flintlastic GTA-FR, Flintlastic GTA-FR Coolstar torch adhered to base or ply sheet.
Surfacing:	Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA: <ol style="list-style-type: none"> <li>1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.</li> <li>2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.</li> </ol>
Maximum Design Pressure:	-45 psf. See General Limitation #9

**Membrane Type:** SBS MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. steel

**System Type D(2):** All layers of insulation and base sheet simultaneously attached.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

**Base Insulation Layer (Optional)**

	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ENRGY 3, ENRGY 3 25 PSI, FlintBoard ISO, H-Shield Minimum 1.5" thick</b>	N/A	N/A
<b>Approved Perlite Insulation Minimum ¾" thick</b>	N/A	N/A
<b>Approved High Density Wood Fiberboard Minimum ½" thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime Minimum ¼" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Approved High Density Wood Fiberboard Minimum ½" thick</b>	N/A	N/A
<b>Approved Perlite Insulation Minimum ¾" thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime Minimum ¼" thick</b>	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base or Flexiglas FR Base mechanically attached as detailed in Fastening #1 or #2, below or one ply of Poly SMS or Ultra Poly SMS mechanically attached as detailed in Fastening #3 or #4, below.

Fastening #1:	OMG #12 Standard Roofgrip or #14 Roofgrip fasteners with OMG 3" Round Metal Plates, Trufast #12 DP Fastener or Trufast #14 HD Fastener with Trufast 3" Metal Insulation Plates, Dekfast 12, Dekfast 14 or Dekfast 15 HS and with Dekfast Galvalume Steel Hex Plates at a 4" side lap 12" o.c. and two rows staggered in the center of the sheet, 24" o.c.
Fastening #2:	OMG #12 Standard Roofgrip or #14 Roofgrip fasteners with OMG 3" Round Metal Plates, Trufast #12 DP Fastener or Trufast #14 HD Fastener with Trufast 3" Metal Insulation Plates, Dekfast 12, Dekfast 14 or Dekfast 15 HS and with Dekfast Galvalume Steel Hex Plates at a 4" side lap 12" o.c. and one row in the center of the sheet, 18" o.c.
Fastening #3:	OMG #12 Standard Roofgrip or #14 Roofgrip fasteners with OMG 3" Round Metal Plates, Trufast #12 DP Fastener or Trufast #14 HD Fastener with Trufast 3" Metal Insulation Plates, Dekfast 12, Dekfast 14 or Dekfast 15 HS and with Dekfast Galvalume Steel Hex Plates at a 4" side lap 12" o.c. and two rows staggered in the center of the sheet, 36" o.c.
Fastening #4:	Trufast #12 DP Fastener or Trufast #14 HD Fastener with Trufast 3" Metal Insulation Plates at a 4" side lap, 12" o.c.
Ply Sheet: (Optional)	One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self-adhered.
Membrane:	One ply of Flintlastic GMS, Flintlastic GMS Coolstar, Flintlastic Premium GMS, Flintlastic Premium GMS Coolstar, Flintlastic FR-P, Flintlastic FR-P Coolstar, Flintlastic Premium FR-P, Flintlastic Premium FR-P Coolstar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet Coolstar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T Coolstar torch adhered to ply sheet
Surfacing:	Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA: <ol style="list-style-type: none"> <li>1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.</li> <li>2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibered Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.</li> </ol>
Maximum Design Pressure:	-45 psf. See General Limitation #9



**Membrane Type:** APP MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. steel deck fastened to structural supports spaced a maximum 5 ft. o.c. with Traxx/5 screws spaced maximum 6 in. o.c. Side laps are fastened with Traxx/1 screws spaced maximum 20 in. o.c.

**System Type D(3):** All layers of insulation and base sheet simultaneously attached.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ENRGY 3, Multi Max FA-3, FlintBoard ISO, H-Shield or Any approved Polyisocyanurate Listed in Table 2</b>		
<b>Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Approved High Density Wood Fiberboard</b>		
<b>Minimum ½" thick</b>	N/A	N/A
<b>Approved Perlite Insulation</b>		
<b>Minimum ¾" thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime</b>		
<b>Minimum ¼" thick</b>	N/A	N/A

**Note:** All layers of insulation and base sheet shall be simultaneously attached. See base sheet below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

**Base Sheet:** One ply of Flexiglas, Flexiglas FR, SBS FR, Poly SMS or Ultra Poly SMS Base Sheet mechanically attached as detailed in Fastening #1 below or one ply of Poly SMS or Ultra Poly SMS Base Sheet mechanically attached as detailed in Fastening #2 below.

**Fastening #1:** OMG #14 Roofgrip Fasteners and OMG 3" Round Metal Plates, Dekfast #14 with Dekfast Galvalume Steel Hex Plates, OMG #14 Roofgrip with 3 in. Ribbed Galvalume Plates or Trufast #14 HD Fastener with Trufast 3" Metal Insulation Plates at a 4" side lap 6" o.c. and two rows staggered in the center of the sheet, 6" o.c. **Minimum Grade 33 steel deck. (Maximum Design Pressure -67.5 psf. ; See General Limitation #7)**

**Fastening #2:** OMG #14 Roofgrip Fasteners and OMG 3" Round Metal Plates, Dekfast #14 with Dekfast Galvalume Steel Hex Plates, OMG #14 Roofgrip with 3 in. Ribbed Galvalume Plates or Trufast #14 HD Fastener with Trufast 3" Metal Insulation Plates at a 4" side lap 12" o.c. and two rows staggered in the center of the sheet, 12" o.c. **Minimum Grade 80 steel deck. (Maximum Design Pressure -120 psf. ; See General Limitation #7)**

Ply Sheet: (Optional)	One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self-adhered or Flintlastic STA torch adhered.
Membrane:	Flintlastic GTA, Flintlastic GTA Coolstar or Flintlastic GTA-FR, Flintlastic GTA-FR Coolstar torch adhered to base or ply sheet.
Surfacing:	Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA: <ol style="list-style-type: none"> <li>1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.</li> <li>2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibered Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.</li> </ol>
Maximum Design Pressure:	See Fastening Above

**Membrane Type:** SBS MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. steel deck fastened to structural supports spaced a maximum 5 ft. o.c. with Traxx/5 screws spaced maximum 6 in. o.c. Side laps are fastened with Traxx/1 screws spaced maximum 20 in. o.c.

**System Type D(4):** All layers of insulation and base sheet simultaneously attached.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ENRGY 3, Multi Max FA-3, FlintBoard ISO, H-Shield or Any approved Polyisocyanurate Listed in Table 2 Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Approved High Density Wood Fiberboard Minimum ½" thick</b>	N/A	N/A
<b>Approved Perlite Insulation Minimum ¾" thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime Minimum ¼" thick</b>	N/A	N/A

**Note:** All layers of insulation and base sheet shall be simultaneously attached. See base sheet below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

**Base Sheet:** One ply of Flexiglas, Flexiglas FR, SBS FR, Poly SMS or Ultra Poly SMS Base Sheet mechanically attached as detailed in Fastening #1 below or one ply of Poly SMS or Ultra Poly SMS Base Sheet mechanically attached as detailed in Fastening #2 below.

**Fastening #1:** OMG #14 Roofgrip Fasteners and OMG 3" Round Metal Plates, Dekfast 14 with Dekfast Galvalume Steel Hex Plates, OMG #14 Roofgrip with 3 in. Ribbed Galvalume Plates or Trufast #14 HD Fastener with Trufast 3" Metal Insulation Plates at a 4" side lap 6" o.c. and two rows staggered in the center of the sheet, 6" o.c. **Minimum Grade 33 steel deck. (Maximum Design Pressure -67.5 psf. ; See General Limitation #7)**

Fastening #2:	OMG #14 Roofgrip Fasteners and OMG 3" Round Metal Plates, Dekfast #14 with Dekfast Galvalume Steel Hex Plates, OMG #14 Roofgrip with 3 in. Ribbed Galvalume Plates or Trufast #14 HD Fastener with Trufast 3" Metal Insulation Plates at a 4" side lap 12" o.c. and two rows staggered in the center of the sheet, 12" o.c. <b>Minimum Grade 80 steel deck. (Maximum Design Pressure -120 psf. ; See General Limitation #7)</b>
Ply Sheet: (Optional)	One ply of All Weather/Empire Base Sheet, GlasBase, Flexiglas Base, Flexiglas FR Base, Poly SMS, Ultra Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self-adhered.
Membrane:	One ply of Flintlastic GMS, Flintlastic GMS Coolstar, Flintlastic Premium GMS, Flintlastic Premium GMS Coolstar, Flintlastic FR-P, Flintlastic FR-P Coolstar, Flintlastic Premium FR-P, Flintlastic Premium FR-P Coolstar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet Coolstar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T Coolstar torch adhered to ply sheet
Surfacing:	Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA: <ol style="list-style-type: none"> <li>1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.</li> <li>2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibered Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.</li> </ol>
Maximum Design Pressure:	See Fastening Above

**Membrane Type:** APP/SBS MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., type B, Grade 80 steel, fastened to structural supports spaced a maximum 5 ft. o.c. with Traxx/5 screws spaced maximum 6 in. o.c. Side laps are fastened with Traxx/1 screws spaced maximum 20 in. o.c.

**System Type D(5):** All layers of insulation and base sheet simultaneously attached.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ENRGY 3, Multi Max FA-3, FlintBoard ISO, H-Shield or Any approved Polyisocyanurate Listed in Table 2</b>		
<b>Minimum 1.5" thick</b>	<b>N/A</b>	<b>N/A</b>

**Note:** All layers of insulation and base sheet shall be simultaneously attached. See base sheet below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

**Base Sheet:** One ply of Ultra Poly SMS Base Sheet mechanically attached as detailed in Fastening below. Lap shall be heat welded.

**Fastening:** Trufast #15 EHD Fastener with Trufast 2.4" Barbed Metal Seam Plates space 12" o.c. in a 4" side lap. The lap is heat welded closed encapsulating the fastener row.

**Ply Sheet:** None

**Membrane:** Flintlastic GTA, Flintlastic GTA Coolstar, Flintlastic GTA-FR, Flintlastic GTA-FR Coolstar or Flintlastic FR Cap T or Flintlastic FR Cap T Coolstar torch adhered to base sheet.

**Surfacing:** Optional for mineral surfaced Membranes. Required for smooth surfaced membranes. Any coating, listed below, used as a surfacing, must be listed within a current NOA:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq.
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating, at an application rate of 1½ gal./sq. or APOC Sunbrite at an application rate of 3 gal./sq.

**Maximum Design Pressure:** -60 psf. (See General Limitation #7)

**Membrane Type:** SBS MODIFIED

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., type B, Grade 80 steel, fastened to steel supports spaced maximum 5 ft. o.c. with Traxx/5 screws spaced maximum 6 in. o.c. Side laps are fastened with Traxx/1 screws spaced maximum 20 in. o.c.

**System Type D(6):** All layers of insulation and base sheet simultaneously attached.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any approved Polyisocyanurate Listed in Table 2, Approved EPS, Approved High Density Wood Fiberboard, Approved Perlite, DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board</b>		
<b>Any thickness</b>	<b>N/A</b>	<b>N/A</b>

**Note:** All layers of insulation and base sheet shall be simultaneously attached. See base sheet below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

**Base Sheet:** One ply of Poly SMS or Ultra Poly SMS Base Sheet mechanically attached as detailed in Fastening below.

**Fastening:** OMG #14 Roofgrip Fasteners and OMG 3" Round Metal Plates, Dekfast 14 with Dekfast Galvalume Steel Hex Plates, OMG #14 Roofgrip with 3 in. Ribbed Galvalume Plates or Trufast #14 HD Fastener with Trufast 3" Metal Insulation Plates fastened 12-inch o.c. in the 4-inch wide lap and 12-inch o.c. in two equally spaced staggered rows in the field.

**Ply Sheet:  
(Optional)** One ply of Flintlastic FR Base T, torch adhered to base sheet.

**Membrane:** Flintlastic FR Cap T or Flintlastic FR Cap T Coolstar, torch adhered to base or ply sheet.

**Maximum Design  
Pressure:** -112.5 psf. (See General Limitation #7)

## STEEL DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

**Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

## END OF THIS ACCEPTANCE



NOA No.: 13-0702.02  
Expiration Date: 01/02/18  
Approval Date: 12/19/13  
Page 31 of 31